

Sheet 110: Revised quantities as follows:

- Cable Trench Type 1 - decrease 81 LF.
- Underground conductor No. 6 Type RHW - decrease 70 LF.
- Underground conductor No. 6 Type THW - decrease 35 LF.
- 2 inch diameter rigid conduit - increase 56 LF.

Sheet 123: Moved feed point from station 22+91-38' Rt. to station 22+22-40' Lt. and revised conduit and conductor runs.

Sheet 124: Revised quantities as follows:

- Underground Conductor No. 2 Type RHW - increase 24 LF.
- Cable Trench - Type 1 - decrease 84 LF.
- Underground Conductor No. 6 Type RHW - decrease 318 LF.
- Underground Conductor No. 6 Type THW - decrease 147 LF.
- Underground Conductor No. 8 RHW - decrease 27 LF.
- 2 inch Diameter Rigid Conduit - increase 85 LF.

Sheet 143: Revised feed point details.

Sheet 145: Revised Lighting Schematics from light standard 11 to 8.

The following plan sheets are being revised at the contractor's request. These revisions shall be at the contractor's own expense:

Sheet 139: Moved conduit and conductor from the east side of the bridge to the west side of the bridge.

Sheet 140: The following revisions:

- Cable Trench - Type 1 - decrease 53 LF.
- Underground Conductor No. 6 Type RHW - increase 218 LF.
- Underground Conductor No. 6 Type THW - increase 109 LF.
- 2 inch Diameter Rigid Conduit - Bridge Mounted - increase 161 LF.